MARYLAND DEPARTMENT OF THE ENVIRONMENT

1800 Washington Boulevard • **Suite 620** • Baltimore, Maryland 21230-1719
(410) 537-3442 • 1-800-633-6101 • http://www.mde.state.md.us

LAND MANAGEMENT ADMINISTRATION
Oil Control Program
Report of Observations

Case # FEB 28 2012

Type of Inspection/Observations: New Permit

Date: 2012-OPT-2861

Site/Facility Name: Reich's Ford Road Landfill

Facility ID # 2361

Location: 9031 Reichs Ford Road LANDFILL - FREDERICK

Page # 1 of 1

Remarks:

The new permit shall be issued in 2-3 weeks. The permit may contain additional requirements not listed in this report. The permit shall require the following:

1) Remove the ~~oil~~ diesel from the Route wall P of the 500 gallon diesel tank (4). Determine if the tank is leaking or not.
2) Replace all PVC bung caps with steel caps
3) Install an emergency vent on the 275 gallon used oil tank (11)
4) Install a normal on the ~~27~~ 250 gallon diesel generator tank (17)
5) Label all tanks with the product stored and the tank's capacity
6) Label all empty tanks as being empty
7) Notify the Department in writing regarding the addition of any aboveground tanks

Compliance shall be 90 days from the date of inspection. Notify the Department in writing upon completion.

Copy of report left on site

Phil Harris

Observer: Albert Simkins [signature]

Person Interviewed: [signature]

Form Number MDE/WAS/Com.031
TTY Users 1-800-735-2258
(Revised 4-10)

Recycled Paper