

New Roads with Sidewalks and Ramps

Road Name	Road Type	Prefix	Suffix	Status	Subdivision/Area Name	Total LF of sidewalk	LF		Number of driveways	Number of ramps	non-compliant ramps	Number of Non-Compliant Features Based on 2019 Inspection						
							compliant sidewalk	number of driveways				sidewalk	driveway cross slope	panel cross slope	narrow sidewalk	vertical clearance	pinch point	passing zone
ALAN LINTON	BOULEVARD	WEST	New	Linton	2796	2796	22	16										
ARBORETUM	DRIVE		New	Landsdale	663	663		13										
BALLINGER CREEK	PIKE		Transfer	Ballenger Creek Pike	9850	9850		25										
BALLINGER CREEK	PIKE		Infill	Ballenger Creek Pike	2712	2712	1	13										
BARNSWALLOW	PLACE		Correction	Meadow at New Market	833	754	14					3	20				7	
CASSIDY	COURT		New	Canal Run	1569	1569	13	2										
CHERRY TREE	COURT		Transfer	West Winds	190	103	1						22					
CHRISTIAN KEMP	DRIVE	NORTH	New	Linton	2446	2446	21	7										
CHRISTIAN KEMP	DRIVE	SOUTH	New	Linton	2045	2045	10	8										
COBLENTZ	ROAD		Correction	Middletown	1654	1388		11					66				4	
CRESTRIDGE	COURT		Transfer	Hannover	853	786	13					2	17				2	
DECATUR	DRIVE		Correction	Green Hill Manor	1294	909							96				1	
DEWEY	WAY		Correction	Greenview	211	211	3										2	
DISPATCH	WAY		New	Linton	1712	1712	21	2										
DREXAL	AVE		Correction	Greenview	1408	1319	15					1	15				7	
EAGLEHEAD	DRIVE		New	Eaglehead	4379	4379		28										
EASTERDAY	ROAD		Infill	Myersville	396	396	2	2										
ELEANOR	DRIVE		New	Linton	3155	3155	32	2										
ELMER DERR	ROAD		Infill	Linton	1389	1389												
ENGLISH MUFFIN	WAY		New	Linton	3553	3553		8										
GIBBONS	ROAD		Correction	Point of Rocks	520	424	6									4		1
GLOWING HEARTH	WAY		New	Landsdale	3252	3252	31	6										
GOVERNORS	WAY		Infill	Omega Center	319	319		3										
HAZELCROFT	AVE		Correction	Greenview	723	703							5				3	
HOLIDAY	DRIVE		Infill	FSK Mall	194	194		2										
HOLTER	ROAD		Infill	Middletown	55	55		2										
HOPEWELL	STREET		New	Eaglehead	1967	1967		14										
HORAN	COURT		New	Windsor Knolls	1305	1305	11	4										
KANAWHA	AVE		Correction	Point of Rocks	347	30	2					1	79				1	
LANDSDALE	BOULEVARD		New	Landsdale	1240	1240		11										
LANDSDALE	PARKWAY		New	Landsdale	978	978												
MAE WADE	AVE		Correction	Green Hill Manor	786	786										5		
MERCANTILE	DRIVE	EAST	Transfer	Hannover	2452	2249		10					51				2	
MILL	STREET		New	Libertytown	303	303	2											
MOUNTVILLE	ROAD		Correction	Adamstown	472	151	3						80			1		
NEW DESIGN	ROAD		Correction	New Design	391	391		2										
NEW HORIZON	WAY		Correction	FSK Mall				4										
NEWPORT	DRIVE	EAST	New	Spring Ridge	392	392		2										
NEWPORT	DRIVE	WEST	New	Spring Ridge	550	550		4										
OAKDALE SCHOOL	ROAD		New	Eaglehead	2474	2474		8										
NATIONAL	PIKE	OLD	Correction	Meadow at New Market	312	312										3		
PANORAMA	DRIVE		Transfer	West Winds	2046	459	15					1	397					
PARTNERS	COURT		New	Crestwood	466	466												

PATINA ROW	WAY	New	Landsdale	1165	1165	8					
PAYTON	WAY	New	Linton	1434	1434	17					
PEGASUS	COURT	Infill	Omega Center	673	673		8				
PROSPECT HILL	PLACE	Correction	Villages of Urbana	412	412						
SHAMROCK	DRIVE	New	Landsdale	2764	2764	30	4				
STONE BARN	DRIVE	New	Villages of Urbana	3859	3859		26				
SWAINS LOCK	COURT	New	Point of Rocks	165	165		1				
SWITZER BARN	LANE	New	Linton	1188	1188	15	2				
TOTTENHAM	STREET	Correction	Villages of Urbana	976	976	7					
TOTTENHAM	STREET	Infill	Villages of Urbana	132	132						
TURF	COURT	NORTH	New	Manorwood	1061	1061	13				
URBANA	PARKWAY		New	Urbana Office Park	4176	4176	3	4			
URBANA	PIKE	Infill	Villages of Urbana	398	398	0	7				
URBANA	PIKE	Transfer	Urbana	3252	3006	3	32	5			
WATERSIDE	DRIVE	Correction	Waterside	210	210		1				
WELLSPRING	COURT	Correction	Meadow at New Market	552	493	10			2	15	3
WESLEY	SQUARE	New	Linton	616	616	7					
WHETSTONE	DRIVE	Correction	Farmbrook	1153	1078	12			2	19	9
WINMOOR	DRIVE	New	Windsor Knolls	3909	3909	31					
YEAGER	COURT	New	Yeager	750	750	6	1	1			

	Number of sidewalk inventory entries	Total LF of sidewalk	compliant sidewalk	number of driveways	Number of ramps	compliant ramps	Number of non-compliant sidewalk	Total Number of Non-Compliant Features Based on 2019 Inspection					
								driveway cross slope	panel cross slope	narrow sidewalk	vertical clearance	pinch point	passing zone
Summary of 2014-2018 System Additions:	63	93,497	89,600	400	295	57	12	882	0	52	0	2	1
2014-2018 Additions Compliant sidewalk:				95.8%	compliant ramps:								
Pedestrian Facilities Subject to 2014 Agreement:	434	812,457		5,270	2,382								
System Growth:	14.5%		11.5%		7.6%	12.4%							

Notes:

1. Status categories:

New - Newly constructed roads with sidewalks accepted into the County system since 2014 survey.

Infill - Sidewalks constructed along existing County roads since 2014 survey.

Transfer - Roads with sidewalks that were under another agency's jurisdiction in 2014 and have since been transferred to the County.

Correction - Roads with sidewalks that were part of County system during 2014 survey but were not recorded during 2014 survey.

2. Ramps in rights-of-way areas not maintained by Frederick County are not included on this list. Ramps in SHA rights of way are not included on this list.

3. Comparison with Ramps and Sidewalks subject to 2014 Agreement based on 2019 Update corrected inventory totals.